


MANUAL MODE OPERATION:

1. SWITCH IS REQUIRED TO TURN LOAD ON.
2. LOAD TURNS OFF WHEN SENSOR TIMES OUT OR WITH SWITCH.

AUTOMATIC MODE OPERATION:

1. WHEN SENSOR ACTIVATES, LOAD TURNS ON.
2. SWITCH CAN BE USED TO TURN LOAD ON OR OFF.
3. IF DAYLIGHT SENSOR IS ENABLED AND LIGHT LEVEL IS ABOVE SETPOINT, SWITCHPACK CONNECTED TO YELLOW LEAD WILL NOT TURN LOAD ON.

RECOMMENDED WIRE:  
18-3 AWG STRANDED WIRE SHIELDED OR NON-SHIELDED



NOTES

1. LOADS MAY BE ON SAME CIRCUIT OR DIFFERENT CIRCUITS OR VOLTAGES.
2. SP20-MV SWITCHPACK SHOWN, 120/277VAC 20AMP RATING.

NOTES:

1. SENSOR TYPE INCLUDE OAC-P-0500-R, OAC-P-1500-R, OAC-U-0501-R, OAC-U-1000-R, OAC-U-2000-R, OAC-DT-0501-R, OAC-DT-1000-R, OAC-DT-2000-R.
2. SP20-MV SWITCHPACK SHOWN. REFER TO CUT SHEETS AND/OR INSTALLATION INSTRUCTIONS FOR OTHER GREENGATE SWITCHPACK WIRING.



Tel: 1-800-553-3879  
Fax: 1-800-954-7016  
Addr: 203 Cooper Circle  
Peachtree City, GA 30269, USA  
ControlsSales@cooperindustries.com  
www.coopercontrol.com

PROJECT			
CEILING SENSOR WIRING DIAGRAM			
TITLE			
SINGLE SENSOR ONE CIRCUIT SINGLE LEVEL THREE-WAY AUTOMANUAL ON/OFF CONTROL			
DWG NO.	DATE	DRAWN BY	CHECKED BY
C2-1ST-1-2L V3-000	05-29-2013	CHKBY	APPRBY
REV.			
A			